

Zone 7 Water Agency Delivered Water PFAS Quarterly Summary* - 2026 Quarter 1 (Q1)

PFAS, parts per trillion (ppt)	Federal		State				MGDP		SRTP		COLTP		HOP 6		HOP 9		DVWTP		PPWTP		
	PQL	Anticipated MCL**	CCRD L	NL	RL	RL Exceedance Methodology	Q1	QRAA	Q1	QRAA	Q1	QRAA	Q1	QRAA	Q1	QRAA	Q1	QRAA	Q1	QRAA	
Perfluorooctanesulfonic acid (PFOS)	4.0	4.0	2.0	4.0	40	QRAA	OOS	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	NS	ND	ND	ND
Perfluorooctanoic acid (PFOA)	4.0	4.0	2.0	4.0	10	QRAA	OOS	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	NS	ND	ND	ND
Perfluorobutanesulfonic acid (PFBS)	3.0	HI=1***	2.0	500	5,000	Single, confirmed sample	OOS	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	NS	ND	ND	ND
Perfluoroheptanoic acid (PFHpA)	NA	NA	2.0	NA	NA	NA	OOS	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	NS	ND	ND	ND
Perfluorohexanesulfonic acid (PFHxS)	3.0	10; HI=1***	2.0	3.0	10	QRAA	OOS	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	NS	ND	ND	ND
Perfluorononanoic acid (PFNA)	4.0	10; HI=1***	2.0	NA	NA	NA	OOS	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	NS	ND	ND	ND
Perfluorodecanoic acid (PFDA)	NA	NA	2.0	NA	NA	NA	OOS	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	NS	ND	ND	ND
Perfluorododecanoic acid (PFDoA)	NA	NA	2.0	NA	NA	NA	OOS	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	NS	ND	ND	ND
Perfluorohexanoic acid (PFHxA)	NA	NA	2.0	1,000	10,000	QRAA	OOS	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	NS	ND	ND	ND
Perfluoroundecanoic acid (PFUnA)	NA	NA	2.0	NA	NA	NA	OOS	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	NS	ND	ND	ND
Hexafluoropropylene oxide dimer acid (HFPO-DA)(GenX)	5.0	10; HI=1***	2.0	NA	NA	NA	OOS	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	NS	ND	ND	ND
9-chlorohexadecafluoro-3-oxanone-sulfonic acid (9CL-PF3ONS)	NA	NA	2.0	NA	NA	NA	OOS	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	NS	ND	ND	ND
11-chloroeicosalfluoro-3-oxaundecane-s-ulfonic acid (11CL-PF3OUdS)	NA	NA	2.0	NA	NA	NA	OOS	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	NS	ND	ND	ND
4,8-dioxa-3H-perfluorononanoic acid (ADONA)	NA	NA	2.0	NA	NA	NA	OOS	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	NS	ND	ND	ND
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	NA	NA	2.0	NA	NA	NA	OOS	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	NS	ND	ND	ND
Perfluorobutanoic acid (PFBA)	NA	NA	2.0	NA	NA	NA	OOS	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	NS	ND	ND	ND
1H,1H,2H,2H-Perfluorodecane sulfonic acid (8:2FTS)	NA	NA	5.0	NA	NA	NA	OOS	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	NS	ND	ND	ND
Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	NA	NA	2.0	NA	NA	NA	OOS	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	NS	ND	ND	ND
Perfluoroheptanesulfonic acid (PFHpS)	NA	NA	2.0	NA	NA	NA	OOS	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	NS	ND	ND	ND
1H,1H,2H,2H-Perfluorohexane sulfonic acid (4:2FTS)	NA	NA	2.0	NA	NA	NA	OOS	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	NS	ND	ND	ND
Perfluoro-3-methoxypropanoic acid (PFMPA)	NA	NA	2.0	NA	NA	NA	OOS	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	NS	ND	ND	ND
Perfluoro-4-methoxybutanoic acid (PFMBA)	NA	NA	2.0	NA	NA	NA	OOS	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	NS	ND	ND	ND
1H,1H,2H,2H-Perfluorooctane sulfonic acid (6:2FTS)	NA	NA	5.0	NA	NA	NA	OOS	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	NS	ND	ND	ND
Perfluoropentanoic acid (PFPeA)	NA	NA	2.0	NA	NA	NA	OOS	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	NS	ND	ND	ND
Perfluoropentanesulfonic acid (PFPeS)	NA	NA	2.0	NA	NA	NA	OOS	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	NS	ND	ND	ND

Notes:

* PFAS monitoring per State Water Board PFAS General Order #DW 2022-0001-DDW (amended January 29, 2026)

** In May 2025, the EPA announced its intent to rescind the PFAS regulation and propose a new rule this fall. This new rule would extend compliance deadlines for PFOA and PFOS from 2029 to 2031 and reconsider regulatory determinations for the other four PFAS. Compliance will be determined by calculating the Running Annual Average (RAA) of sample results. If a sample result is less than the Practical Quantitation Limit (PQL), a zero is used for the RAA calculation. For more information, visit www.epa.gov/sdwa/and-polyfluoroalkyl-substances-pfas

*** HI = Hazard Index. HI applies to any mixture containing two or more of PFNA, PFHxS, PFBS, and GenX. These PFAS can often be found together in different mixtures and research shows that exposure to mixtures of these chemicals may have additive health impacts. HI is calculated as follows:

$$\text{Hazard Index (1 unitless)} = \left(\frac{[\text{HFPO-DA}]_{\text{ppt}}}{[10 \text{ ppt}]} \right) + \left(\frac{[\text{PFBS}]_{\text{ppt}}}{[2000 \text{ ppt}]} \right) + \left(\frac{[\text{PFNA}]_{\text{ppt}}}{[10 \text{ ppt}]} \right) + \left(\frac{[\text{PFHxS}]_{\text{ppt}}}{[10 \text{ ppt}]} \right)$$

Abbreviations:

PFAS = Per- and polyfluoroalkyl substances
 QRAA = Quarterly Running Annual Average
 PQL = Practical Quantitation Level
 MCL = Maximum Contaminant Level
 CCRDL = Consumer Confidence Report Detection Level
 NL = Notification Level
 RL = Response Level

NA = Not Applicable/Not Available
 ND = Non-Detect; Value equal or less than CCRDL
 NS = Not Sampled
 OOS = Out-of-Service

Treatment Plants:

MGDP = Mocho Groundwater Demineralization Plant
 SRTP = Stoneridge Treatment Plant
 COLTP = Chain of Lakes Treatment Plant
 DVWTP = Del Valle Water Treatment Plant
 PPWTP = Patterson Pass Water Treatment Plant